



MEC-TRIC CONTROL COMPANY
 411 0 MONROE ROAD
 P.O. BOX 221918
 CHARLOTTE, N.C. 28222
 (704) 376-8555
 FAX (704) 375-1728

Control Number V/UV

M3-2988-1

Assembly Order

Sold To

Novo Nordisk Pharmaceutical
 3612 Powhatan Road
 City State Zip
 Clayton NC 27520
 Cust. Order No.: 4501388726

Ship To

Novo Nordisk Pharmaceutical
 645 GLP One Way Gate D
 City State Zip
 Clayton NC 27527
 Date Shipped: November 6, 2023 Shipped Via: UPS

Order Date 1698753600	Customer ID 02-0014828	Date Req. November 9, 2023	Written By Ben Simons
---------------------------------	----------------------------------	--------------------------------------	---------------------------------

Contact: Brian Raby	Email: XBRQ@novonordisk.com	Phone Number:
-------------------------------	---------------------------------------	----------------------

Description

Model Number: 26FA10L-140/SP	Assembled By: CJ	Spring No.: E0357SS	Inlet Size: 1 1/2"	Inlet Connection: 150# Flanged
Set Pressure: 9.5 BarG	Service: Liquid	Orifice: F Orifice	Capacity: 428 LPM	Spring Range: 9.1-9.79 BarG
Outlet Size: 2"	Outlet Connection: 150# Flanged	Over Pressure 10%	BP: 0	
Serial Number: 1012892-1-A14/6	Tagging Instructions:	Temp. 72 F	Special Instructions: SP - SS Spring 9.5 BarG = 137.78 PSIG	

MATERIAL REQUISITION

SHOP

Description	MCC-C	Drawn From Stock	Date Ordered	Nameplate Code Stamping			
				Code Stamping:	Reason - Not Code Stamped :		
47-26FA10L	1441.44	1		UV			
48-4K26140AD-N	537.84	1		Date: November 9, 2023	Tester: CJ	C.I.: CJ	
N48-E0357SS	251.83	0	October 31, 2023	Date Completed: November 11, 2023	Seals: Conley Jones	Tag: Conley Jones	
		0		Test Media: Water	Cert. Lift In Inches :	Set: 9.5 BarG	B.D.: 24
				B.P.: 0	Over Pressure: 10%	Leak Tight To: PSIG	
				Dyn Or Static	Dynamic	Gauge No: DPG-7	
				Simmer		CDTP@: N/A	
				Pop	138	B.P. TEST @: Yes	
				Reseat	114	Number Of Notches: -5	
				B.D.	24	Leak: No	