



MEC-TRIC CONTROL COMPANY
 411 0 MONROE ROAD
 P.O. BOX 221918
 CHARLOTTE, N.C. 28222
 (704) 376-8555
 FAX (704) 375-1728

Control Number V/UV
M3-3218-1

Assembly Order

Sold To

ALBEMARLE CORP US
 348 HOLIDAY INN DRIVE
 City State Zip
 KINGS MOUNTAIN NC 28086
 Cust. Order No.: 02-0011737

Ship To

ALBEMARLE CORP US
 348 HOLIDAY INN DRIVE
 City State Zip
 KINGS MOUNTAIN NC 28086
 Date Shipped: November 27, 2023 Shipped Via: UPS

Order Date 11/16/2023	Customer ID 61806	Date Req.	Written By Rudy Flint
---------------------------------	-----------------------------	------------------	---------------------------------

Contact:	Email:	Phone Number:
-----------------	---------------	----------------------

Description

Model Number: 27CA13-M40	Assembled By: CJ	Spring No.: C3009SS	Inlet Size: 1/2"	Inlet Connection: MNPT
Set Pressure: 50 PSIG	Service: Liquid	Orifice:	Capacity: 12 GPM	Spring Range: 49-56 PSIG
Outlet Size: 1"	Outlet Connection: FNPT	Over Pressure 10%	BP: 0	
Serial Number: 1027605-1-KE	Tagging Instructions:	Temp. 72 F	Special Instructions:	

MATERIAL REQUISITION

SHOP

Description	MCC-C	Drawn From Stock	Date Ordered	Nameplate Code Stamping			
47-27CA13M20	325.78	1		Code Stamping: UV		Reason - Not Code Stamped :	
48-C3009SS	18.13	1		Date:		Tester: CJ	C.I.: CJ
N48-4K27140A	292.10	0	November 16, 2023	Date Completed: November 22, 2023		Seals: Conley Jones	Tag: Conley Jones
		0		Test Media: Water	Cert. Lift In Inches : 0	Set: 50 PSIG	B.D.: 15.0 PSIG
				B.P.: 0	Over Pressure: 10%	Leak Tight To: 45.0 PSIG	
				Dyn Or Static	Dynamic	Gauge No: DPG-7	
				Simmer	0	CDTP@: N/A	
				Pop	50.0 PSIG	B.P. TEST @: N/A	
				Reseat	35.0 PSIG	Number Of Notches: N/A	
				B.D.	15.0 PSIG	Leak: No	